

# ADVANCED GENERATORS

(SOUTH)

825 Gatepark Dr. #11  
Daytona Beach, FL 32114  
(386) 304-1999 • Fax (386) 252-1747

Unit 1

SERVICE ORDER 019040

INVOICE DATE \_\_\_\_\_  
DATE REC'D 11/3/23

OWNER NAME <i>Baysshore Bath &amp; Tennis</i>	MFG OF ENGINE	MFG OF EQUIPMENT <i>Cummins</i>
STREET ADDRESS <i>925 N Halifax Ave</i>	SPEC CODE OR AGR NO.	MODEL NO.
CITY, STATE & ZIP <i>Daytona Bch FL 32118</i>	SERIAL / CODE / D.O.M. NO. / CPL	SERIAL NO.
CUSTOMER PHONE NO. <i>Rachel 255-3686</i>	VLN#	SPEC NO.
CUSTOMER COMMENTS: <i>Semi Annual Inspect</i>		HOURS <i>144.8WS</i>

DIAGNOSTICS/REPAIRS PERFORMED:

- Performed SEM-ANNUAL INSPECTION.  
- BLOW HEATER FANLEY & MELTED OUTLET. NEEDS OUTLET & BLOW HEATER  
- CUSTOMER WOULD LIKE DIESEL TREATMENT ADDED TO TANK (6.50 gallon)

PART NUMBER	DESCRIPTION	QTY	UNIT PRICE	AMOUNT	SERVICE SUMMARY
					PARTS
					LABOR HRS _____
					QUOTED OR OUTSOURCED WORK
					S & H
					MISC
					BATTERY FEE / ENVIRONMENTAL FEE
					SHOP SUPPLIES
					<b>SUB</b>
					<b>TAX</b>
					<b>TOTAL AMOUNT</b>
					DEPOSIT AMOUNT
					CC FEE
					AMOUNT DUE
					PAYMENT AMOUNT

PLEASE NOTE

- While the manufacturer may warrant the goods sold to the customer, we make no warranties, express or implied, including any implied warranties of merchantability or fitness, with respect to such goods.
- I hereby authorize the above repair work to be done along with the necessary material and hereby grant you and / or your employees permission to operate the unit as necessary for the purpose of testing and / or inspection. An express mechanic's lien is hereby acknowledged on above unit to secure the amount of repairs thereto.
- Not responsible for loss or damage in case of fire, theft or any other cause beyond our control. X SIGNED \_\_\_\_\_

IF EQUIPMENT IS NOT CLAIMED AFTER 90 DAYS IT WILL BECOME PROPERTY OF ADVANCED GENERATORS.

CLAIM CHECK 019040

SERVICE I.D. TAG

019040

# INSPECTION CHECK SHEET

# ADVANCED GENERATORS

Name Baysshore Beach & Tennis  
 Address 925 N. Halifax Ave  
D. B.

825 Gatepark Drive #11 - Daytona Beach  
 (386) 304-1999 - Fax (386) 252-1747

Date 11/2/23

Hours 144.8hrs

EQUIPMENT TYPE: GENERATOR / FIRE PUMP Unit 1

INSPECTION: M Q SA A

PROCEDURES	CK'D	NOTES	BATTERIES			
			Voltage #1	Voltage #2	Voltage Drop #1	Voltage Drop #2
Batteries	OK	9/22				
Battery Fluid Level	N/A					
Battery Load Test	OK	9.40VDC / 9.39VDC	12.65VDC	12.65VDC	9.40	9.39
Battery Specific Gravity	OK		GENERATOR			
Fuel System	OK	Di - 3/4	Phase #1 AC Volts	Phase #2 AC Volts	Phase #3 AC Volts	Frequency
Fuel Filters	OK	no date	200VAC	200VAC	200VAC	60 Hz
Air Intake System	OK		REMARKS / RECOMMENDATIONS			
Exhaust System	OK					
Air Filter	OK					
Louvers	N/A					
Engine Safeties	OK					
Coolant System	OK	162°F				
Oil Filters	OK					
Lube System	OK	75 PSI				
Oil	OK					
Block Heater	X	faulty outlet				
Engine Battery Charger	OK	14.04VDC / 14.07				
Float / Trickle Charger	OK	12.65VDC / 12.65VDC				
Day Tank System	N/A					
Engine RPM	OK	1000				
Electrical Connections	OK					
Cables & Harnesses	OK					
Pump Packing	N/A					
Operation	OK					
Manual Start Sys	OK		Tech Initials <u>AP</u>			

(NORTH)

Unit 2

# ADVANCED GENERATORS

825 Gatepark Dr. #11  
Daytona Beach, FL 32114  
(386) 304-1999 • Fax (386) 252-1747

SERVICE ORDER 019041

INVOICE DATE \_\_\_\_\_  
DATE REC'D 11/2/23

OWNER NAME <b>Bayshore Bath &amp; Tennis</b>	MFG OF ENGINE	MFG OF EQUIPEMENT <b>Cummins</b>
STREET ADDRESS <b>925 N Halifax Ave</b>	SPEC CODE OR AGR NO.	MODEL NO.
CITY, STATE & ZIP <b>Daytona Beach FL 32118</b>	SERIAL / CODE / D.O.M. NO. / CPL	SERIAL NO.
CUSTOMER PHONE NO. <b>Rachel 255-3686</b>	VLN#	SPEC NO.
CUSTOMER COMMENTS: <b>Semi-Annual Inspect.</b>	HOURS <b>168.2 Hrs</b>	

DIAGNOSTICS/REPAIRS PERFORMED:

- PERFORMED SEMI-ANNUAL INSPECTION.
- FULLY BLACK HEATER.
- CUSTOMER WOULD LIKE ~~FUEL~~ FUEL TREATMENT ADDED TO TANK (650 gal)

PART NUMBER	DESCRIPTION	QTY	UNIT PRICE	AMOUNT	SERVICE SUMMARY
					PARTS
					LABOR HRS _____
					QUOTED OR OUTSOURCED WORK
					S & H
					MISC
					BATTERY FEE / ENVIRONMENTAL FEE
					SHOP SUPPLIES
					<b>SUB</b>
					<b>TAX</b>
					<b>TOTAL AMOUNT</b>
					DEPOSIT AMOUNT
					CC FEE
					AMOUNT DUE
					PAYMENT AMOUNT

**PLEASE NOTE**

- While the manufacturer may warrant the goods sold to the customer, we make no warranties, express or implied, including any implied warranties of merchantability or fitness, with respect to such goods.
- I hereby authorize the above repair work to be done along with the necessary material and hereby grant you and / or your employees permission to operate the unit as necessary for the purpose of testing and / or inspection. An express mechanic's lien is hereby acknowledged on above unit to secure the amount of repairs thereto.
- Not responsible for loss or damage in case of fire, theft or any other cause beyond our control. X SIGNED \_\_\_\_\_

IF EQUIPMENT IS NOT CLAIMED AFTER 90 DAYS IT WILL BECOME PROPERTY OF ADVANCED GENERATORS.

CLAIM CHECK 019041

SERVICE I.D. TAG

019041

# INSPECTION CHECK SHEET

# ADVANCED GENERATORS

Name Dayshore Bath & Tennis  
 Address 925 N Halifax Ave  
Daytona Bch

825 Gatepark Drive #11 - Daytona Beach  
 (386) 304-1999 - Fax (386) 252-1747

Date 11/12/23

Hours 168.2 Hrs

EQUIPMENT TYPE: GENERATOR / FIRE PUMP Unit 2

INSPECTION: M Q SA A

PROCEDURES	CK'D	NOTES	BATTERIES			
			Voltage #1	Voltage #2	Voltage Drop #1	Voltage Drop #2
Batteries	OK	8/22	13.19VDC	13.12VDC	9.52VDC	9.52VDC
Battery Fluid Level	OK					
Battery Load Test	OK	19.09VDC				
Battery Specific Gravity	OK		GENERATOR			
Fuel System	OK	D1-5/8 <sup>ths</sup> Full	Phase #1 AC Volts	Phase #2 AC Volts	Phase #3 AC Volts	Frequency
Fuel Filters	OK	5-2-23	208VAC	208VAC	208VAC	60 HZ
Air Intake System	OK		REMARKS / RECOMMENDATIONS			
Exhaust System	OK					
Air Filter	OK		Unit needs new block heater			
Louvers	N/A					
Engine Safeties	OK					
Coolant System	OK	163°F				
Oil Filters	OK	5-2-23				
Lube System	OK	72 PSI				
Oil	OK					
Block Heater	OK					
Engine Battery Charger	OK	28.11				
Float / Trickle Charger	OK	26.92VDC				
Day Tank System	OK	Full				
Engine RPM	OK	1800				
Electrical Connections	OK					
Cables & Harnesses	OK					
Pump Packing	N/A					
Operation	OK					
Manual Start Sys	OK		Tech Initials <u>AP</u>			